

February 4, 2010

REVISED

ACCESSIBLE SYSTEMS, LLC
DAVID SHUSTERICH, PRESIDENT
2940 WEEKS AVE SE
MINNEAPOLIS MN 55414

Re: Description: SINK, SHAMPOO
Manufacturer: ACCESSIBLE SYSTEMS, LLC
Product Name: ADJUST-A-SINK
Model Number(s): K100
Product File No: 20090409

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 31, 2014.

This approval is contingent upon compliance with the following stipulation(s):

- When using a Marble Products 3000W shampoo bowl - Marble Products 3 in 1 Faucet/Spay/Vacuum Breaker, MP#800, 1014U Fixture. This faucet meets ASME A112.18.1 which includes approved backflow protection device(s).
- When using a Belvedere shampoo bowl - Belvedere 503 Vacuum Breaker shall be used. This Vacuum Breaker meets ASSE 1014.
- The vertical distance between the top of the fixture drain outlet and the horizontal center line of the trap outlet shall not exceed 15 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov